

Henry's Service All

1012 Luke Street Irving, TX 75061

Office: 972-986-4006 Fax: 972-986-3677

www.HenrysServiceAll.com

HenrysServiceAll@verizon.net



Here's what we did for you today on your Heat System checkup:

- 1 Inspected Pilot Light
 - 2 Checked Safety Limits
 - 3 Checked gas connections
 - 4 Checked gas valve operation
 - 5 Checked Thermostat for proper functioning and battery supply (Asked customer if new settings are needed and set them)
 - 6 Inspected Motor
 - 7 Inspected Heat Exchanger
 - 8 Inspected Air Filter (HSA will supply a new filter at an additional cost)
 - 9 Completed Carbon Monoxide Test
 - 10 Tested Smoke Detectors (Smoke Test will be conducted at an additional cost, if necessary)
 - 11 Wrote down model and serial numbers for all equipment on work order
 - 12 Wrote filter size on work order
 - 13 Noted overall performance of the HVAC unit on the work order
- *Any batteries needed will be provided for customer at an additional cost

☐ Your system is working well at this time. If something goes wrong in the next 30 days, call us and we will tell you how to get a 10% discount on the repair.

☐ The technician noted concerns with your unit on the work order. Make sure to call the office and schedule the repair today! Ask how to receive 10% off the repair.

License Information:

Texas State Board of Plumbing Examiner
PO Box 4200

929 East 1st Street
Austin, TX 78765

License # M-14612 Henry Nuckolls, RMP

Electrical Contractor

License # TECL 22933

Texas Department of Licensing and Regulations

PO Box 12157
Austin, Texas 78765

800-803-9202

A/C & Refrigerant

License # TACLA 004331E